

**Addendum #3
July 16, 2018**

City of Marengo

**Marengo 2018 Watermain Replacement Project
Job No.: 86140346.02**

This addendum forms a part of the bidding documents and contract documents and modifies the original bidding documents certified June 14, 2018. Acknowledge receipt of this addendum in the space provided on the Bid Form and attach and sign with your Proposal. **Failure to do so may subject the Bidder to disqualification.**

PROJECT MANUAL

Section 00400, Section 3:

- Remove “Combined Total of US 20 and IL 23 Base Bid = \$ _____.” from end of section.
- Remove “Combined Total of US 20 and IL 23 Alternate Bid = \$ _____.” from end of section.

CLARIFICATION

- Separate awards will be based on lowest responsible bidders. There will be bid awarded for lowest responsible bidder for US 20 and another for IL 23.
- Restoration is limited to 15’ around watermain as shown on plans and all other restoration not shown is incidental.
- While casing of long water services is not required by IDOT, IEPA requires casing if water services cross under sanitary sewer service or, if they are less than 18 inches above.
- IDOT Bond amounts currently are \$50,000 for US 20 and \$120,000 for IL 23. Contractors shall post bonds. If bond amounts are revised in final IDOT review, increase in bond cost is incidental to bid.
- Tree bores are incidental to bid.
- Sanitary sewer main is all that needs to be pre and post construction televised and not services.

This Addendum #3 **must** be attached and signed with your Proposal.

Received _____, 2018

Contractor _____