

**WASTEWATER TREATMENT SYSTEM UPGRADE
RIVERSIDE, IOWA**

CONTRACTOR'S BID DATE: February 24, 2022 @ 1:00 P.M.

PLACE FOR CONTRACTORS
TO SUBMIT BIDS:

Highland Community School District
NE Entrance, Conference Room on Right
1715 Vine Avenue
Riverside, IA

ADDENDUM NO. 1
February 8, 2022

TO ALL PLANHOLDERS:

The following changes, clarifications, additions, and/or deletions are hereby made a part of the contract documents for the above-referenced project, as fully and completely as if the same were fully set forth therein.

This Addendum No. 1 consists of the following:

- Addendum No. 1 pages ADN1-1 through ADN1-2

NOTES AND CLARIFICATIONS:



1. *There are no* domestic or American Iron and Steel (AIS) requirements for this project.
2. *For* ductile iron pipe penetrations into precast structures, use Detail 11 on Sheet C501 as referred to in Note 4 on Sheet P103. For existing concrete penetrations, use Detail 13 on Sheet C501 as referred to in Note 5 on Sheet P103.
3. For MH 1780, 4020, 4180 and 5180 use the typical 4' diameter precast SUDAS manhole 301 per Keynote 5 on Sheet C101.
4. Hydromatic is an acceptable manufacturer for pumps.
5. Valmatic is an acceptable manufacturer for plug valves.
6. There is no demo of pipe in the softball field.
7. Gravity sanitary sewer pipe shall be SDR26 as shown on the plans.

8. Materials surrounding structures not explicitly covered in other bid items may be included with the structures.
9. MH-1504 is existing as shown on sheet G005.
10. Detail 17 of Sheet C501 shows the section view of the pipe weir in MH 4180 and 5180. The weir pipes in MH 4020 use a bend instead of a tee and do not have a drain tap as shown on sheet P104.

SPECIFICATIONS:

1. In specification Section 09 9000, under systems 3A and 4A, **REPLACE** "Series 1 Omnithane" with "N140 Pota-Pox Plus" as the primer.

All bidders shall acknowledge receipt and acceptance of Addendum No.1 by signing in the space provided on the Bid Form. Bids submitted without Addendum No.1 being acknowledged will be considered non-responsive.

	I hereby certify that this engineering document was prepared by me or under my direct personal supervision and that I am a duly licensed Professional Engineer under the laws of the State of Iowa.
	 _____ IAN CORBIN, P.E.
	Date: <u>2/08/22</u>
	License No. 25370
	My renewal date is December 31, 2022
Pages or sheets covered by this seal: Addendum #1 _____ _____	

IAN CORBIN
HR GREEN, INC.
8710 EARHART LANE
CEDAR RAPIDS, IOWA 52404
PHONE: (319) 841-4000

END OF ADDENDUM #1