

**WASTEWATER TREATMENT SYSTEM UPGRADE
RIVERSIDE, IOWA**

CONTRACTOR'S BID DATE: February 24, 2022 @ 1:00 P.M.

PLACE FOR CONTRACTORS
TO SUBMIT BIDS: Highland Community School District
NE Entrance, Conference Room on Right
1715 Vine Avenue
Riverside, IA

ADDENDUM NO. 2
February 11, 2022

TO ALL PLANHOLDERS:

The following changes, clarifications, additions, and/or deletions are hereby made a part of the contract documents for the above-referenced project, as fully and completely as if the same were fully set forth therein.

This Addendum No. 2 consists of the following:

- Addendum No. 2 pages ADN2-1 through ADN2-2


NOTES AND CLARIFICATIONS:

SPECIFICATIONS:

1. REFER TO SECTION 33 3220 SEPTIC TANK SYSTEM

- a. **DELETE** 2.02 J. "The roof hatch located over the ships ladder shall include a handrail extension that is secured to the hatched with type 316 stainless steel hardware. The handrail extension shall be inline with the handrail on the ships ladder when the hatch is fully open and shall be minimum of 18-inches long. Handrail extension shall be constructed of 1-1/4" diameter, Schedule 40, 6005-T5 aluminum pipe with 6005-T5 aluminum base plates."

All bidders shall acknowledge receipt and acceptance of Addendum No.2 by signing in the space provided on the Bid Form. Bids submitted without Addendum No.2 being acknowledged will be considered non-responsive.

	<p>I hereby certify that this engineering document was prepared by me or under my direct personal supervision and that I am a duly licensed Professional Engineer under the laws of the State of Iowa.</p>
	<p><i>Ian Corbin</i> _____ IAN CORBIN, P.E. License No. 25370 My renewal date is December 31, 2022 Pages or sheets covered by this seal: Addendum #2 _____ _____</p>

IAN CORBIN
HR GREEN, INC.
8710 EARHART LANE
CEDAR RAPIDS, IOWA 52404
PHONE: (319) 841-4000

END OF ADDENDUM #2