

**Addendum #2**

**Village of Western Springs**

**Water Treatment Plant Engine Generator  
HRG Job No.: 210251**

**February 8, 2022**

This addendum forms a part of the bidding documents and contract documents and modifies the original bidding documents certified January 21, 2022. Acknowledge receipt of this addendum in the bid submittal and attach and sign with your Proposal. **Failure to do so may subject the Bidder to disqualification.**

**INFORMATION/CLARIFICATION**

Section 26 3213 – Using ComEd utility bills, Engineer verified that peak kW at the Water Treatment Plant is 290 kW. Therefore, Bidder shall disregard paragraph 2.03 Loading Sequence. Generator shall be sized for a minimum power rating of 350 kW as per 26 3213, 2.02.D.2 and 2.02.J.

This Addendum #2 **must** be attached and signed with your Proposal.

Received \_\_\_\_\_, 2022

Contractor \_\_\_\_\_