

**WASTEWATER TREATMENT SYSTEM UPGRADE
RIVERSIDE, IOWA**

CONTRACTOR'S BID DATE: February 24, 2022 @ 1:00 P.M.

PLACE FOR CONTRACTORS
TO SUBMIT BIDS:

Highland Community School District
NE Entrance, Conference Room on Right
1715 Vine Avenue
Riverside, IA

ADDENDUM NO. 5
February 18, 2022

TO ALL PLANHOLDERS:

The following changes, clarifications, additions, and/or deletions are hereby made a part of the contract documents for the above-referenced project, as fully and completely as if the same were fully set forth therein.

This Addendum No. 5 consists of the following:

- Addendum No. 5 pages ADN 5-1 through ADN 5-2

SPECIFICATIONS:

1. **REFER TO SECTION 33 3216 FACILITY PACKAGED SEWER PUMPING STATIONS**
 - a. **2.03.A.1.:** **DELETE** "4.125 inch impeller diameter."
 - b. **3.03.B.:** **REPLACE** "9.86 ft and 9.95 ft" with "10.4 ft TDH"
 - c. **3.03.C.:** **REPLACE** "48" gpm and 20 gpm" with "minimum 35 gpm and not to exceed 50 gpm at rated head"
 - d. **3.03.C.:** **DELETE** "1. Rim elev – 762.67", "2. Invert elev – 751.17", "7. Inlet pipe size – 6 in and 4 in", and "8. Inlet pipe invert – see drawings"
 - e. **3.03.C.3.:** **REPLACE** "752.67" with "753.00"
 - f. **3.03.C.4.:** **REPLACE** "752.00" with "752.17"
 - g. **3.03.C.5.:** **REPLACE** "753.00 [Where both pumps kick on]" with "755.50"
 - h. **3.03.C.6.:** **REPLACE** "High water elev" with "high water alarm elev"



PLANS:

1. **REFER TO SHEET C103 PAVING PLAN**
 - a. **DELETE** KEYNOTES "2. NEW EQUIPMENT GRAVEL SEE DETAIL 1/C501."
2. **REFER TO SHEET C501 DETAILS**
 - a. **DELETE** Detail 5

3. REFER TO SHEET P101, P102 AND P103

- a. The circular manholes into the tanks shall be 24" diameter with concrete covers.

All bidders shall acknowledge receipt and acceptance of Addendum No.5 by signing in the space provided on the Bid Form. Bids submitted without Addendum No.5 being acknowledged will be considered non-responsive.

	I hereby certify that this engineering document was prepared by me or under my direct personal supervision and that I am a duly licensed Professional Engineer under the laws of the State of Iowa.
	 _____ Date: <u>2/18/22</u>
	IAN CORBIN, P.E.
	License No. 25370
	My renewal date is December 31, 2022
Pages or sheets covered by this seal: Addendum #5	

IAN CORBIN
HR GREEN, INC.
8710 EARHART LANE
CEDAR RAPIDS, IOWA 52404
PHONE: (319) 841-4000

END OF ADDENDUM #5