

ADDENDUM No. 1

June 6, 2022

Subject: *LINCOLNWOOD MANOR SUBDIVISION STREET RECONSTRUCTION
VILLAGE OF CARPENTERSVILLE
SECTION NUMBER 21-00092-00-FP*

To Prospective Bidders:

This Addendum is issued to all registered plan holders pursuant to the Instructions to Bidders and Conditions of the Contract. This Addendum serves to clarify, revise, and supersede information in the Project Manual, Drawings, and previously issued Addenda. Portions of the Addendum affecting the Contract Documents will be incorporated into the Contract by enumeration of the Addendum in the Owner/Contractor Agreement.

The Bidder shall acknowledge receipt of this Addendum in the appropriate space on the Bid Form. Bids submitted without Addendum No. 1 being acknowledged may be considered non-responsive.

Please note the following regarding questions, clarifications, and interpretations:

Reference to the following Special Provisions found within the bidding documents as stated under section:

PREQUALIFICATION OF BIDDERS

Prequalification of bidders in accordance with Check Sheet LRS6 of the Supplemental Specifications and Recurring Special Provisions will be required of all bidders on this proposal. IDOT prequalification in category 003 HMA Plant Mix will be required of all bidders on this proposal.

Response: The statement “IDOT prequalification in category 003 HMA Plant Mix will be required of all bidders on this proposal” will be removed in its entirety and therefore deleted from the special provisions requirement. This requirement was a carryover from the Village’s previous resurfacing projects at that time.

Question: Item #29 Agg Base CSE B - 1,974 TN
Where is this supposed to be used, we cannot find a call out for it?

Response: This pay item was for consideration (means and method) to bring up portion of the utility trench in the temporary or interim condition after utility installation and prior to removal of the full pavement section to provide access or ability to cross the “void” in the utility trench and existing pavement if left in place.

Contractors must utilize the enclosed material when preparing their bid. The signed copy of ADDENDUM No. 1 must be included with the submitted Proposal.

No Proposal shall be considered responsive, nor shall any Proposal be considered unless the appropriate space for acknowledgement of the addendum is completed in the original bid package and unless the Proposal is accompanied by a signed copy of this ADDENDUM No. 1. The signed copy of ADDENDUM No. 1 shall be attached to the Proposal.

The undersigned agrees to be bound by the modifications made within this ADDENDUM No. 1, and hereby waives any and all claims based upon the additional or modified information contained herein.

Acknowledgement of ADDENDUM No. 1

Company Name (Name of Plan Holder): _____

Signature of Company Representative: _____

Printed Name/Title of Company Representative: _____